



Date: 11/24/09


Inspected By:

Andy Sigmon  
Brian Thompson

Project: Richmond County Judicial Center

Contractor: Paramount Contracting

1. Rivets in back flashing (not covered by MRS warranty)
2. Rivets in valley (not covered by MRS warranty)
3. Caulk around zee closure
4. Close ridge off with end cap
5. Turn ridge under panels and caulk
6. Extend Ridge under joggle cleat
7. Exposed screws not covered under MRS warranty
8. Ridge needs to be locked and riveted
9. Lapped panels
10. Screws in knees/knuckles
11. Check all panels and seams as needed
12. Needs panel
13. Check and add knees/knuckles where needed
14. Place end cap and caulk
15. Remove all scraps off roof.



Roof Panel Plan

DRAWING  
NO  
**1**



**METAL ROOFING**  
Systems, Inc.



