




METAL ROOFING
Systems, Inc

MRS System 2000 16" 24 Ga.

ASTM E1592 Wind Uplift Test

Metal Roofing Systems Inc., had its MRS System 2000 structural standing seam panel tested per ASTM E1592 on March 31, 2006.



TEST RESULTS

Panel	Gauge	Span	Ultimate Load (psf)	Design Load (psf) Factor of Safety = 1.65 (CEGS)	Design Load (psf) Factor of Safety = 2.00 (AISI*)
MRS System 2000 16"	24	1'-0"	63.6	38.5	42.4
MRS System 2000 16"	24	2'-0"	53.2	32.2	35.5
MRS System 2000 16"	24	5'-0"	42.8	25.9	28.5

Test Report No. : T110-06

Dated : March 31, 2006